



Town of Ridgeland

June 28, 2024

PROJECT: Town of Ridgeland Well Site No. 3 Improvements
TOR-2024-05

ADDENDUM: One (1)

DUE DATE: Tuesday, July 2, 2024 at 2:00 PM

THIS ADDENDUM IS FOR THE PURPOSE OF MAKING THE FOLLOWING CHANGES OR CLARIFICATIONS:

- 1. How has the scope varied since the project originally bid a couple months ago? Besides bid alternate line item pricing the scope appears to be very similar, please confirm.**

The scope of work is the same as the original bid. The bid form has been modified as you noted to assist with the grant agency review/approval.

- 2. Plan Sheet C3- Note #1, states the well can be offline for up to one week, please confirm this is accurate? It will need to be offline for much longer to complete the scope of work.**

The timeline for the well to be offline will be coordinated with the Town. It will depend on the time of year and operational reliability of the other two system wells/pumps.

- 3. Are alternate pump manufactures acceptable if they meet or exceed the specifications?**

The allowable pump manufacturers are listed in section 11220. The process for requesting a substitute is also described in section 11220 as noted below:

Town of Ridgeland Well Site No. 3 Improvements (TOR 2024-05)

1.4.D Equipment Manufacturers: The vertical turbine pump shall be manufactured by Flowserve, Goulds Water Technology, or Fairbanks Nijhuis. Substitution of equipment by alternate manufacturers will be considered if the equipment proposed for substitution is demonstrably equal or superior in quality and efficiency to the standards established in the specifications and this is demonstrated to the complete satisfaction of the ENGINEER and TOWN. Request for approval of substitute equipment shall be submitted in accordance with Section 00100: Instructions to Bidders. Use of approved alternate manufacturers in no way relieves any manufacturer of strictly adhering to the specification and submittal requirements.

4. Acknowledgement:

The Bidder shall include acknowledgement of the Addendum One (1) in bid by including this form and also acknowledge Addendum One (1) in Section 00300 Bid Proposal Form.

Signature: _____

Date: _____